

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1581:101 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Acme Engineering & Mfg. Corp., P.O. Box 978, Muskogee, OK 74402
Contact: Michael Almaguer (918) 684-0523

DESIGN: Model RD-2, RD-2R, RD-2SB, RD-4, RD-8 and RD-521 ceiling fire dampers. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as ceiling fire dampers for use in assemblies rated up to 3-hour. Authority having jurisdiction should be consulted prior to installation.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

XLF: 3225-0368:104

11-04-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager